

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 557

Dated: 29/02/2024

It is certified that an inspection team headed by **MR. SANJAY KUMRE EXECUTIVE ENGINEER** (Name of Officers with designation) from **PHED CHHATARPUR, (M.P.)** PHED inspected the **GSM ENGLISH SCHOOL, SAGAR ROAD, CHHATARPUR, DIST.- CHHATARPUR, (M.P.)** on 29/02/2024 and on the basis of Water Test Report (Attached) bearing no. 2060/2024 dated 29/02/2024 of **DISTT. WATER TESTING LABORATORY, PHED CHHATARPUR, (M.P.)** (PHED Lab) certified that the **GSM ENGLISH SCHOOL, SAGAR ROAD, CHHATARPUR, DIST.- CHHATARPUR, (M.P.)** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 28/02/2025.

Signature with seal

:-

Name

:- **MR. SANJAY KUMRE**

Designation


:- **EXECUTIVE ENGINEER**Name & address of the office/Department: - **PHED CHHATARPUR, (M.P.)**


To,

**GSM ENGLISH SCHOOL, SAGAR ROAD,
CHHATARPUR, DIST.- CHHATARPUR, (M.P.)**

(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies


Principal
GSM English School
Sagar Road, Chhatarpur (M.P.)


सचिव
गजराज समाज कल्याण समिति
बगौता, जिला-छतरपुर (म.प्र.)

Distt. Water testing Laboratory Public Health Engineering Division Chhatarpur (M.P.)

TEST REPORT

Nature of Sample :- Drinking Water Sample/ Others		Not sampled by Distt.Lab		Unique Identification No.	
Sender's name and address GSM ENGLISH SCHOOL CHHATARPUR (M.P)	Sender's letter No	107/2024	Sender's letter Date	29.2.2024	
	Distt.Lab Ref. No	2060/2024	Receipt date	29.2.2024	
	Date of analysis started	29.2.2024	Date analysis completed	29.2.2024	
	Quantity of Sample				
Sample details					
Particulars of Samples					
NO	1 WATER SAMPLE OF GSM ENGLISH SCHOOL CHHATARPUR (M.P)				
2					
3					

RESULTS

No	Characteristics unit and test methods	BIS-10500-2012 Reframed in June 2015		RESULTS		
		Desirable Limit	Permissible Limit	1	2	3
	2	3	4			
1	Temperature in degree C			28 °C		
2	Colour in Hazen scale	5	15	NIL		
3	Odour	Agreeable	Agreeable	NIL		
4	Iron as Fe mg/l BIS 3025 part 53	1.0	1.0	0.1		
5	Nitrate as No3 mg/l PDA Method	45	45	41		
6	Fluoride as F mg/ltr BIS 3025 part 60	1.0	1.5	0.06		
7	Chloride as Cl in mg/l BIS 3025 part 32	250	1000	144		
8	Total Alkalinity as caco3 in mg/l BIS 3025	200.0	600	320		
9	Calcium as Ca in mg/l BIS 3025 part 40	75	200	76		
10	Magnesium as Mg in mg/l BIS 3025 part 46	30	100	42		
11	Sulphate as SO4 in mg/l BIS 3025 part 24	200	400	144		
12	pH BIS 3025 part 11	6.5 to 8.5	6.5 to 8.5	7.5		
13	Turbidity in NTU BIS 3025 part 10	1.0	5.0	2.6		
14	Total Hardness as CaCO3 in mg/l BIS3025 part 10	200	600	432		
15	Conductivity at 25°C as micromhos/cm2			664		
16	TDS mg/l By Meter	500	2000	98		
17	Manganese as mn in mg/l	0.1	0.3	NIL		
18	Feecal coliform (TTC) per 100 ml	NIL		NIL		
19	Total coliform per 100 ml	NIL for treated water and water in distribution system		NIL		

- This report should not be produced partly or full without approval of signatory authority for legal purpose
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the
- The results refer only to tested samples and parameters tested
- This lab does not hold any responsibility for variation in results for for samples kept on hold for want of clarification.

Remarks:

Principal
GSM English School
Sagar Road, Chhatarpur (M.P)

सचिव
मजराज समाज विकास समिति
बनौत, जिला-उत्तरपुर (म.प्र.)

CHEMIST
Distt. water testing laboratory
P.H.E.D. Chhatarpur (M.P.)
Chemist
Water Testing Laboratory
P.H.E.
Chhatarpur (M.P.)